

REVDL series cable glands are suitable for use in hazardous areas with danger of explosion to enable direct insertion of non-armoured cables into explosion-proof junction boxes, lighting fixtures, plugs and sockets, etc... This series can accommodate smaller cable diameters than the standard required for each measure. In this way, the use of reductions is avoided. They are provided with one sealing ring which tightens the incoming cable ensuring the 'Ex d' way of protection and a second sealing ring that tightens on the outer sheath of the cable to ensure the IP 66/67 degree of protection avoiding the ingress of water, moisture, rain and dust.



<b>Classification:</b> 2014/34/UE	<b>Group II</b>	<b>Category 2GD</b>
<b>Installation:</b> EN 60079-14	<b>zone 1 - zone 2 (Gas)</b>	<b>zone 21 - zone 22 (Dust)</b>
<b>Marking:</b>	<b>CE 0722 Ex II 2 GD - Ex d IIC Gb Ex tb IIIC Db - IP66/67</b>	
<b>Certification:</b>	<b>ATEX</b>	<b>CESI 13 ATEX 019 X</b>
	<b>IECEX</b>	<b>IECEX CES 13.0005X</b>
	<b>TR CU</b>	<b>AVAILABLE</b>
<b>Standards:</b>	CENELEC EN 60079-0: 2012, EN 60079-1: 2007, EN 60079-7: 2007, EN 60079-31: 2009 and European Directive 2014/34/UE IEC60079-0: 2011, IEC60079-1: 2007-04, IEC60079-31: 2008, IEC 60079-7: 2006-07 Directive RoHS 2002/95/CE	
<b>Operating temperature:</b>	<b>-40°C +110°C</b>	
<b>Degree of protection:</b>	<b>IP66/67</b>	

All IEC Ex and TR CU certification data can be downloaded at [www.cortemgroup.com](http://www.cortemgroup.com)

Interactive Point



[REVD assembly instructions video](#)

Certificates are available on [www.cortemgroup.com](http://www.cortemgroup.com)